

جلسه قبل از داوطلبی پروژه تجهیزات کمره های امنیتی و دیجیتال سازی محوطه تعمیر مخابرات و تکنالوژی معلوماتی

تاریخ جلسه : 1404/6/30 مطابق 1447/3/28		مکان جلسه : ریاست تدارکات , طبقه 14 تعمیر 18 منزله وزارت مخابرات و تکنالوژی معلوماتی
شماره	سوال	جواب
1	ایرکندیشن کمپنی مشخص شود ؟	ایرکندیشن ها از شرکت سامسونگ یا معادل آن با کیفیت باشد . AR24TSHZJWK/JO Wall-mount AC with Digital Inverter, 24,000 BTU
2	سه ساکته برقی به کدام کیفیت باشد ؟	سه ساکته های برقی با کیفیت عالی تهیه شود . Power distributing unit 02 meter Power distributing unit 05 meter Power distributing unit 10 meter

مظور کننده

تصدیق کننده

ترتیب کننده

ارایه معلومات و توضیحات به سوالات مطرح شده پروژه تجهیزات کمره های امنیتی و دیجیتال سازی محوطه تعمیر وزارت مخابرات و تکنالوژی معلوماتی

No	Queries	Response
1	(Item no. 27) At the end, 4GB is mentioned; could you please confirm what this refers to? Additionally, do you require Windows 10 Professional with a valid license?	The "4GB" mentioned at the end of Item No. 27 was a typing mistake. Regarding your query, yes, we require Windows 10 Professional with a valid license.
2	Item no 24 how many SFP modules are required for your fiber optic cable setup, and how many cores of splicing are required for your fiber optic instalation?	24 number of SFP and the splicing will required as per the site.in 24 item we need 24 SFP
3	If additional accessories are required during the installation, will you proceed with the purchase?	No, we will not proceed with the purchase of any additional accessories during the installation.
4	You mentioned the 2-inch EMT pipe; do you need this for the outdoor camera or for another purpose?	Yes, the 2-inch EMT pipe will be used for the outdoor camera.
5	You mentioned a 2-inch PVC T; could you clarify what this is for, since your pipe is EMT?	The 2-inch PVC T is intended for use inside the building, where PVC pipes are installed. Outside the building, EMT pipes are used instead.
6	What is the distance between the earthing pit and the earthing busbar?	The distance between the earthing pit and the earthing busbar is 40 to 50 meters.
7	Do you require a metal bracket to be installed on the ground, on which the TV bracket will be mounted?	Yes, we require a metal stand that can hold two screens per stand for installation. The design for the stand has already been attached to the procurement document (Shartnama).

Handwritten signatures and official stamps of the Ministry of Communication and IT, General Directorate of IT Infrastructure. The stamps include the text: "وزارت مخابرات و تکنالوژی معلوماتی", "Ministry Of Communication and IT", "دستورالعملی فناوری و زیرساخت های رایانه", and "General Directorate of IT Infrastructure".