

Pre-Bid Meeting for Nation Internet Exchange Afghanistan (NIXA) Project

شماره داوطلبی : MCIT/1404/NCB/G-17

No	Queries	Response
01	In section 1.2 Regarding Xen Orchestra What is your current existing virtualization platform and what is the use case of Xen Orchestra?	The Ministry of Communications and IT (MCIT) currently uses XCP-ng as its primary virtualization platform. Implementing Xen Orchestra will provide centralized VM management, real-time monitoring, automated backup, and advanced orchestration, enhancing efficiency, reliability, and security across the infrastructure.
02	In section 1.2 Regarding Xen Orchestra which flavor you need the main issue is with sanctions on Afghanistan and governmental entities? In this case what is your opinion.	MCIT requires the Enterprise version of Xen Orchestra to meet functionality and support requirements. However, due to international sanctions affecting procurement in Afghanistan, bidders may propose equivalent alternative solutions with similar capabilities.
03	In section 1.2, 2.2 and 2.4 you have mentioned complete Training, is it on-job knowledge transfer?	Yes, the complete training mentioned in Sections 1.2, 2.2, and 2.4 refers to on-job knowledge transfer training. This means the vendor's technical team will train MCIT's IT staff directly during the implementation and configuration process, ensuring they gain hands-on experience and the practical skills needed to manage, maintain, and troubleshoot the system independently after project completion.
04	In section 2.3 Regarding Fortinet Analyzer please describe the use case in addition Do you have any Fortinet firewall currently in you network? If yes please provide the model and serial number	- The use case of Fortinet FortiAnalyzer will be deployed as the main event analyzer for centralized logging, security analytics, reporting, and real-time alerting to enhance monitoring and response across the network. - MCIT currently has two FortiGate firewalls, both model F3201. The serial numbers are FG32F1TB24900068 & FG32F1TB24900060.
05	In section 3.1 Regarding STULZ HVAC spare parts you only need the Spare Parts supply?	Yes, in Section 3.1 regarding STULZ HVAC, we only require the supply of spare parts. No additional services such as installation or maintenance are included in this scope.



06	In section 3:1 regarding STULZ HVAC spare parts we need HVAC Model and Serial Number?	The Model Number is 2009 and the Serial Number is 05300900051/01-02.
07	In section 4.1 you mentioned installation, configuration, testing and migration, please provide more specific detail where we need installation, configuration, testing and migration?	As mentioned in the BoQ, all items except those listed in Section 3 (STULZ HVAC spare parts) require installation, configuration, testing.

شماره	سوالات	توضیحات
01	با استفاده از سیستم بک آپ گیری Veeam، کدام موارد باید تحت بک آپ گیری قرار گیرند؟	• با استفاده از سیستم Veeam، موارد زیر باید تحت بک آپ قرار گیرند: • ماشین های مجازی (VMs) در محیط های VMware، Hyper-V، XCP-ng و سایر پلتفرم ها • سرورهای فیزیکی در صورت نیاز • دیتابیس ها مانند PostgreSQL، Oracle، و غیره ایمیل ها و سرویس های CWP/Postfix
02	آیا می توانیم تجهیزات دیگر را نیز پیشنهاد دهیم؟	مطابق طرز العمل تدارکات شما می تواند تجهیزات معادل را با در نظر داشت عین مشخصات و کیفیت عالی پیشنهاد کنید
02	مبلغ تضمین آفر در اعلان داوطلبی پروژه به حروف به مبلغ نه میلیون نه صد و ده هزار اما به عدد (910,000) افغانی تحریر گردیده است. کدام یکی صحت است معلومات داده شود.	مبلغ تضمین آفر به مبلغ نه صد و ده هزار (910,000) افغانی صحت می باشد که در شرطنامه صادره و نشر شده اداره نیز به مبلغ نه صد و ده هزار (910,000) افغانی ذکر شده و قابل تطبیق است.
03	آیا امکان همکاری به شکل اشتراکی با سایر شرکت ها وجود دارد؟	بلی، مطابق به مندرج شرطنامه نامه نشر شده اداره قابل تطبیق است.
04	آیا می توانیم تجهیزات را از چندین شرکت تهیه و تدارک کنیم؟	بلی
05	آموزش باید به چه شکل باشد به حضوری یا آنلاین و به چه تعداد پرسونل آموزش میشود؟	مطابق به مندرج شرطنامه نامه نشر شده اداره قابل تطبیق است.

